



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: October 2021

FlowCon ADP

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Differential Pressure, Balancing and Control Valve with Adjustable Insert

ADP.0 and **ADP.1** in A/AB/ABV1-housing DN15/20/25

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 25 bar

Conformity assessment followed

All sizes and configurations of the FlowCon ADP valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen
Quality and Sourcing Manager

FlowCon
international

A Griswold Controls LLC./FlowCon International Company

www.flowcon.com

DENMARK • DUBAI • USA • CHINA • SINGAPORE