



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: January 2020

FlowCon E-JUST

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Automatic Balancing Valve with Adjustable Insert

E-JUST1.Y.B, E-JUST1.Y.G, E-JUST1.Y.R, E-JUST1.G.B, E-JUST1.G.G and E-JUST1.G.R
in A/AB/ABV1-housing DN15/20/25

E-JUST2.Y.G in AB-housing DN25/32 or ABV2-housing DN25/32/40

E-JUST3.G.B in AB-housing DN40/50

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 25 bar

Conformity assessment followed

DN15/20/25/32 sizes and configurations of the FlowCon E-JUST valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

DN40/50 in the configuration of the FlowCon E-JUST valve listed above conform to Category I (procedure A).

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen
Quality and Sourcing Manager

FlowCon
international

A Griswold Controls LLC/FlowCon International Company

www.flowcon.com

DENMARK • DUBAI • USA • CHINA • SINGAPORE