



# **FlowCon Certificate of Conformity**

## **Pressure Equipment Directive 2014/68/EU**

**Date:** July 2024

### **FlowCon Essentia**

**Manufacturer**

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

**Description of the pressure equipment**

Adjustable Pressure Independent Automatic Balancing Control Valve (PICV)

**Essentia** DN15/20/25

Fluid Group 2

Temperature range: -20/+100°C

Static pressure: 25 bar

**Conformity assessment followed**

All sizes and configurations of the FlowCon Essentia valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

**References of the harmonized Standards**

EN 12266-1/2:2012 / EN 12165:2016 / EN 10204:2004

**Authorized on behalf of FlowCon International ApS**

Ms. Christina Cohr  
Chief Commercial Officer

**FlowCon**  
*international*

A Griswold Controls LLC./FlowCon International Company

[www.flowcon.com](http://www.flowcon.com)

DENMARK • DUBAI • USA • CHINA • SINGAPORE