

FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: September 2020

FlowCon FIT-G

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Pressure Independent Automatic Balancing and Temperature Control Valve with Adjustable Insert FIT-G.0 and FIT-G.1 in AB -housing DN15/20/25 FIT-G.2 in AB-housing DN25/32 Fluid Group 2 Temperature range: -20/+120°C Static pressure: 25 bar

Conformity assessment followed

All sizes and configurations of the FlowCon FIT-G valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen Quality and Sourcing Manager



Page 1 of 1

A Griswold Controls LLC./FlowCon International Company

– www.flowcon.com —



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: September 2020

FlowCon FIT-G.3

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Adjustable Pressure Independent Automatic Balancing and Temperature Control Valve FIT-G.3 DN40/50 Fluid Group 2 Temperature range: -20/+120°C Static pressure: 25 bar

Conformity assessment followed

All sizes and configurations of the FlowCon FIT-G valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen Quality and Sourcing Manager



Page 1 of 1

A Griswold Controls LLC./FlowCon International Company

– www.flowcon.com —