



# FlowCon Certificate of Conformity

## Pressure Equipment Directive 2014/68/EU

**Date:** September 2020

### FlowCon GreEQ

**Manufacturer**

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

**Description of the pressure equipment**

Pressure Independent Automatic Balancing Control Valve with Adjustable Equal% Insert (PICV)

**GreEQ.0** and **GreEQ.1** in A/AB/ABV1-housing DN15/20/25

**GreEQ.2** in AB-housing DN25/32 or ABV2-housing DN25/32/40

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 25 bar

**Conformity assessment followed**

DN15/20/25/32 sizes and configurations of the FlowCon GreEQ valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

DN40 in the configuration of the FlowCon GreEQ valve listed above conforms to Category I (procedure A).

**References of the harmonized Standards**

EN 12516 / EN13445 / EN10204-3.1

**Authorized on behalf of FlowCon International ApS**

Mr. Finn Christensen  
Quality and Sourcing Manager

**FlowCon**  
*international*

A Griswold Controls LLC./FlowCon International Company

[www.flowcon.com](http://www.flowcon.com)

DENMARK • DUBAI • USA • CHINA • SINGAPORE