



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: May 2025

FlowCon Metering Station MS.15

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Metering Station with venturi

MS.15-1 Kvs 0.26

MS.15-2 Kvs 0.55

MS.15-3 Kvs 1.15

MS.15-4 Kvs 2.80

MS.15-5 Kvs 5.40

DN15

Fluid Group 2

Temperature range: -20°C to +130°C

Static pressure: 25 bar (up to 100°C) / 20 bar (above 100°C)

Conformity assessment followed

All configurations of the FlowCon Metering Station valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. Such units shall not bear the 'CE' marking.

References of the harmonized Standards

EN 12266-1+2:2012 / DS/EN 10204:2004 / EN 12165:2024

Authorized on behalf of FlowCon International ApS

Ms. Christina Cohr
Chief Commercial Officer

FlowCon
international

A Griswold Controls LLC./FlowCon International Company

www.flowcon.com

DENMARK • DUBAI • USA • CHINA • SINGAPORE