



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: November 2020

FlowCon Extended Metering Station MS 15

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Metering Station with Venturi

MS15-1 KVS 0,263

MS15-2 KVS 0,55

MS15-3 KVS 1,15

MS15-4 KVS 2,8

MS15-5 KVS 5,4

DN15

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: PN 25 bar Test pressure 37,5 bar

Conformity assessment followed

All sizes and configurations of the FlowCon Metering Station valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen
Quality and Sourcing Manager

FlowCon
international

A Griswold Controls LLC/FlowCon International Company

www.flowcon.com

DENMARK • DUBAI • USA • CHINA • SINGAPORE