

# FlowCon Certificate of Conformity

# **Pressure Equipment Directive 2014/68/EU**

**Date:** February 2020

# FlowCon PIMTM-DP

#### Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

### **Description of the pressure equipment**

Adjustable Differential Pressure Control Valve PIMDP.0.J DN65/80 PIMDP.0.K DN80/100

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 16 bar

#### Conformity assessment followed

All sizes and configurations of the FlowCon PIM<sup>TM</sup>-DP valve listed above conform to Category I (procedure A).

## References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen

Quality and Sourcing Manager

FlowCon

A Griswold Controls LLC./FlowCon International Company

- www.flowcon.com -

Page 1 of 1