



# **FlowCon Certificate of Conformity**

## **Pressure Equipment Directive 2014/68/EU**

**Date:** February 2020

### **FlowCon Partner Ball**

**Manufacturer**

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

**Description of the pressure equipment**

Partner Ball Valve  
**PBV** DN15/20/25/32/40/50  
Fluid Group 2  
Temperature range: -20/+120°C  
Static pressure: 35 bar

**Conformity assessment followed**

DN15/20/25/32 sizes and configurations of the FlowCon Partner Ball valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.  
DN40/50 in the configuration of the FlowCon Partner Ball valve listed above conform to Category I (procedure A).

**References of the harmonized Standards**

EN 12516 / EN13445 / EN10204-3.1

**Authorized on behalf of FlowCon International ApS**

Mr. Finn Christensen  
Quality and Sourcing Manager

**FlowCon**  
*international*

A Griswold Controls LLC/FlowCon International Company

[www.flowcon.com](http://www.flowcon.com)

DENMARK • DUBAI • USA • CHINA • SINGAPORE