

FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: November 2020

FlowCon PURE

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Automatic Balancing Valve with Built-in Pre-set Flow Limiter

F494.8xx DN40/50

Fluid Group 2

Temperature range: 0/+200°C

Static pressure: 30 bar

Conformity assessment followed

DN40/50 in the configuration of the FlowCon PURE valve listed above conform to Category I (procedure A).

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen

Quality and Sourcing Manager



Page 1 of 1

A Griswold Controls LLC./FlowCon International Company