



# **FlowCon Certificate of Conformity**

## **Pressure Equipment Directive 2014/68/EU**

**Date:** April 2021

### **FlowCon Unimizer® 2-way**

**Manufacturer**

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

**Description of the pressure equipment**

2-Way Actuated Control Valve

**FUR2** DN15/20/25/32/40/50/65/80

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 25 bar

**Conformity assessment followed**

DN15/20/25/32 sizes of the FlowCon Unimizer® 2-way valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

DN40/50/65/80 sizes of the FlowCon Unimizer® 2-way valve listed above conform to Category I (procedure A).

**References of the harmonized Standards**

EN 12516 / EN13445 / EN10204-3.1

**Authorized on behalf of FlowCon International ApS**

Mr. Finn Christensen  
Quality and Sourcing Manager

**FlowCon**  
*international*

A Griswold Controls LLC/FlowCon International Company

[www.flowcon.com](http://www.flowcon.com)

DENMARK • DUBAI • USA • CHINA • SINGAPORE



# **FlowCon Certificate of Conformity**

## **Pressure Equipment Directive 2014/68/EU**

**Date:** April 2021

### **FlowCon Unimizer® 2-way**

**Manufacturer**

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

**Description of the pressure equipment**

2-Way Actuated Control Valve

**FUR2** DN100/125/150

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 16 bar

**Conformity assessment followed**

All sizes of the FlowCon Unimizer® 2-way valve listed above conform to Category I (procedure A).

**References of the harmonized Standards**

EN 12516 / EN13445 / EN10204-3.1

**Authorized on behalf of FlowCon International ApS**

Mr. Finn Christensen  
Quality and Sourcing Manager

**FlowCon**  
*international*

A Griswold Controls LLC./FlowCon International Company

[www.flowcon.com](http://www.flowcon.com)

DENMARK • DUBAI • USA • CHINA • SINGAPORE



# **FlowCon Certificate of Conformity**

## **Pressure Equipment Directive 2014/68/EU**

**Date:** April 2021

### **FlowCon Unimizer® 3-way**

**Manufacturer**

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

**Description of the pressure equipment**

3-Way Actuated Control Valve

**FUR3** DN15/20/25/32/40/50/65/80

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 25 bar

**Conformity assessment followed**

DN15/20/25/32 sizes of the FlowCon Unimizer® 3-way valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. As such, these valves will not bear the 'CE' marking.

DN40/50/65/80 sizes of the FlowCon Unimizer® 3-way valve listed above conform to Category I (procedure A).

**References of the harmonized Standards**

EN 12516 / EN13445 / EN10204-3.1

**Authorized on behalf of FlowCon International ApS**

Mr. Finn Christensen  
Quality and Sourcing Manager

**FlowCon**  
*international*

A Griswold Controls LLC/FlowCon International Company

[www.flowcon.com](http://www.flowcon.com)

DENMARK • DUBAI • USA • CHINA • SINGAPORE



# **FlowCon Certificate of Conformity**

## **Pressure Equipment Directive 2014/68/EU**

**Date:** April 2021

### **FlowCon Unimizer® 3-way**

**Manufacturer**

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

**Description of the pressure equipment**

3-Way Actuated Control Valve

**FUR3** DN100/125/150

Fluid Group 2

Temperature range: -20/+120°C

Static pressure: 16 bar

**Conformity assessment followed**

All sizes of the FlowCon Unimizer® 3-way valve listed above conform to Category I (procedure A).

**References of the harmonized Standards**

EN 12516 / EN13445 / EN10204-3.1

**Authorized on behalf of FlowCon International ApS**

Mr. Finn Christensen  
Quality and Sourcing Manager

**FlowCon**  
*international*

A Griswold Controls LLC./FlowCon International Company

[www.flowcon.com](http://www.flowcon.com)

DENMARK • DUBAI • USA • CHINA • SINGAPORE