



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: August 2025

FlowCon SH.1/2 Stainless Steel

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Adjustable Automatic Balancing Valve

SH.1.1 SSL DN15/20/25

SH.2.1 SSL DN25/32/40

Fluid Group 2

Temperature range: -20°C to +120°C

Static pressure: 25 bar

Conformity assessment followed

All sizes of the FlowCon SH valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. Such valves shall not bear the 'CE' marking.

References of the harmonized Standards

DS/EN 10213:2007+A1:2016 + AD 2000-Merkblatt W5 / DS/EN 10204:2004 / DS/EN 1559-2:2014

Authorized on behalf of FlowCon International ApS

Ms. Christina Cohr
Chief Commercial Officer

FlowCon
international

A Griswold Controls LLC/FlowCon International Company

www.flowcon.com

DENMARK • DUBAI • USA • CHINA • SINGAPORE



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: August 2025

FlowCon SH.3/4 Stainless Steel

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Adjustable Automatic Balancing Valve

SH.3.0 SSL, SH.3.1 SSL, SH.3.2 SSL DN50/65/80

SH.4.1 SSL, SH.4.2 SSL, SH.4.3 SLL DN80/100

Fluid Group 2

Temperature range: -20°C to +120°C

Static pressure: 40 bar

Conformity assessment followed

All sizes of the FlowCon SH valve listed above conform to Category I (procedure A).

References of the harmonized Standards

DS/EN 10213:2007+A1:2016 + AD 2000-Merkblatt W5 / DS/EN 10204:2004 / DS/EN 1559-2:2014

Authorized on behalf of FlowCon International ApS

Ms. Christina Cohr
Chief Commercial Officer

FlowCon
international

A Griswold Controls LLC/FlowCon International Company

www.flowcon.com

DENMARK • DUBAI • USA • CHINA • SINGAPORE