

FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: August 2025

FlowCon SS Flanged Series Stainless Steel

Importer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Automatic Balancing Valve with Pre-set Insert(s)

F4S.D DN40

F4S.E DN50

F4S.M DN50 high flow

Fluid Group 2

Temperature range: -20°C to +200°C

Static pressure: 18 bar

Conformity assessment followed

All sizes of the FlowCon SS Flanged Series valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. Such valves shall not bear the 'CE' marking.

References of the harmonized Standards

DS/EN 10213:2007+A1:2016 + AD 2000-Merkblatt W5 / DS/EN 10204:2004 / DS/EN 1559-2:2014

Authorized on behalf of FlowCon International ApS

Chief Commercial Officer

FlowCon international

A Griswold Controls LLC./FlowCon International Company

www.flowcon.com -

Page 1 of 2



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: August 2025

FlowCon SS Flanged Series Stainless Steel

Importer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Automatic Balancing Valve with Pre-set Insert(s)

F4S.F DN65/80

F4S.G DN100

F4S.H DN150

F4S.J DN200

Fluid Group 2

Temperature range: -20°C to +200°C

Static pressure: 18 bar

Conformity assessment followed

All sizes of the FlowCon SS Flanged Series valve listed above conform to Category I (procedure A).

References of the harmonized Standards

DS/EN 10213:2007+A1:2016 + AD 2000-Merkblatt W5 / DS/EN 10204:2004 / DS/EN 1559-2:2014

Authorized on behalf of FlowCon International ApS

Ms. Christina Cohr

Chief Commercial Officer



A Griswold Controls LLC./FlowCon International Company

www.flowcon.com -

Page 2 of 2