



FlowCon Certificate of Conformity

Pressure Equipment Directive 2014/68/EU

Date: August 2025

FlowCon Wafer Stainless Steel

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Automatic Balancing Valve with Pre-set Insert(s)

F3.25.x.B SSL DN50

F3.26.x.B SSL DN65/80

F3.32.x.B SSL DN100

F3.34.x.B SSL DN150

F3.37.x.B SSL DN200

Fluid Group 2

Temperature range: -20°C to +135°C

Static pressure: 16 bar

Conformity assessment followed

DN50 of the FlowCon Wafer valve listed above conform to Article 4, Paragraph 3 (Sound Engineering Practice) of the PED Directive 2014/68/EU. Such valves shall not bear the 'CE' marking.

All other sizes of the FlowCon Wafer valve listed above conform to Category I (procedure A).

References of the harmonized Standards

EN13445-6:2021 / EN 12516-1+2:2003 / DS/EN 10204:2004 / EN 1563:2018/RET.1:2021

Authorized on behalf of FlowCon International ApS

Ms. Christina Cohr
Chief Commercial Officer

FlowCon
international

A Griswold Controls LLC./FlowCon International Company

www.flowcon.com

DENMARK • DUBAI • USA • CHINA • SINGAPORE